



Certificate of Compliance

Certificate: 1094571

Master Contract: 158806

Project: 2550391

Date Issued: November 30, 2012

Issued to: Hotstart Inc.
5723 E Alki
Spokane, WA 99212
USA
Attention: James Hunt

The products listed below are eligible to bear the CSA Mark shown



James Lim

Issued by: James Lim

PRODUCTS

CLASS 2878 02 - HEATERS - Miscellaneous - For Hazardous Locations

CLASS 4868 01 - TEMPERATURE-INDICATING AND REGULATING EQUIPMENT -
For Hazardous Locations

Part 1

CLASS

2878-02 HEATERS - Miscellaneous - For Hazardous Locations

PRODUCTS

Class I, Division 1, Group D; Temperature Code T3C.

Lube Oil Heaters; Series "OE" Rated 277V max, 650W max, 50/60Hz single phase.

Part 2

CLASS

4868-01 TEMPERATURE-INDICATING AND REGULATING EQUIPMENT - For Hazardous Locations



Certificate: 1094571

Master Contract: 158806

Project: 2550391

Date Issued: November 30, 2012

PRODUCTS

Class I, Division 1, Group D; Temperature Code T3C.

Thermostat Assembly; Model DITXXEP, 15 A 120 V AC, 13 A 240 V AC, 9 A 277 V AC, Max 60°C 'ON', 71°C 'OFF'

Notes:

Model DITXXEP is for the lube oil heater Model "OE" series only. Suitability of this device is subjected to end use application only.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 0-10 - General Requirements - Canadian Electrical Code, Part II

CSA Standard C22.2 No 0.4-04 - Bonding of electrical equipment

CSA Standard C22.2 No 0.5-1982 - Threaded Conduit Entries

CSA Standard C22.2 No 24-1993 - Temperature Indicating and Regulating Equipment

CSA Standard C22.2 No 30-1986 - Explosion-Proof Enclosures for use in Class I Hazardous Locations

CSA Standard C22.2 No 142-1987 - Process Control Equipment.