

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180518-E474204  
**Report Reference** E474204-20180518  
**Issue Date** 2018-MAY-18

**Issued to:** HOTSTART INC  
5723 E ALKI AVE  
Spokane WA 99212

**This is to certify that  
representative samples of**

HEATERS, MISCELLANEOUS FOR USE IN HAZARDOUS  
LOCATIONS  
See Addendum

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 823, ELECTRIC HEATERS FOR USE IN HAZARDOUS  
(CLASSIFIED) LOCATIONS  
CSA C22.2 NO. 30-M1986, EXPLOSION-PROOF  
ENCLOSURES FOR USE IN CLASS I HAZARDOUS  
LOCATIONS  
UL 499, ELECTRIC HEATING APPLIANCES  
UL 574, ELECTRIC OIL HEATERS  
CSA C22.2 NO. 72-10, HEATER ELEMENTS  
CSA C22.2 NO. 88-1958, CONSTRUCTION AND TEST OF  
INDUSTRIAL HEATING EQUIPMENT

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180518-E474204  
**Report Reference** E474204-20180518  
**Issue Date** 2018-MAY-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

EP Series, Cat. Nos. E, followed by 005, 007, 010, 015, 017, 020, 025, 030, 040, 045, 050, 060, 075, 080, 090, 100, 110, 120, 150, 170, 180, 200, 210, 240, 270, 300, 330, or 360, followed by 1, 2, 3, 4, 5, 6, 7, 8, 9, 0, A, B, C, D, E, F, or G, followed by 1 or 3, followed by E-, followed by 05, 10, 15, 20, 25, 30, 40, 50, C0, or C5, followed by N, 4, 6, 8, 1, 2, H, T, R, or J, followed by V, A, S, or B, may be followed by additional numbers. Explosion-proof immersion heaters for use in Hazardous Locations, Class I, Division 1, Groups C and D.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

